STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155697	A. BUILDING 01 B. WING _____	R 04/18/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
CLARK REHABILITATION AND SKILLED NURSING CENTER	517 N LITTLE LEAGUE BLVD CLARKSVILLE, IN 47129

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 03/08/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 04/18/12 Facility Number: 000059 Provider Number: 155697 AIM Number: 100266560 Surveyor: Mark Bugni, Life Safety Code Specialist At this PSR survey, Clark Rehabilitation and Skilled Nursing Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19, Existing Health Care Occupancies and 410 IAC 16.2. This one story facility was determined to be of Type V (000) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and single station smoke detection in the 12 resident rooms on the Front Hall and single station smoke detection in the 11 resident rooms on the 60 Hall. The 40 Hall and 20 Hall resident rooms did not have smoke detection. The facility has a capacity of 100 and had a census of 69 at the time of this visit. Quality Review by Robert Booher, Life Safety	{K 000}		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	155697	A. BUILDING 01 B. WING _____	R 04/18/2012

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
CLARK REHABILITATION AND SKILLED NURSING CENTER	517 N LITTLE LEAGUE BLVD CLARKSVILLE, IN 47129

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
{K 000}	Continued From page 1 Code Specialist-Medical Surveyor on 04/20/12.	{K 000}		